

ANNUAL DRINKING WATER QUALITY REPORT FOR 2011

Incorporated Village of Mineola

167 Elm Place, Mineola, New York 11501

(Public Water Supply ID # 2902839)



Prepared by:

Dvirka and Bartilucci Consulting Engineers
330 Crossways Park Drive, Woodbury, NY 11797

May 2012

Dear Fellow Residents and Merchants,

I am pleased to present the 2011 Annual Water Quality Report for the Incorporated Village of Mineola.

The Village of Mineola Water Department operates your water production and delivery systems. The Water Department carefully and regularly tests the water pumped from our wells and delivered through our piping system in order to assure that it is of the highest quality possible. We adhere to the strictest standards for protecting our water supply and for safe and sanitary delivery to you, our consumers.

The Board of Trustees and I consider quality water production and delivery very important responsibilities, and, in so doing, have undertaken the rehabilitation of our wells, the installation of purification systems, the servicing of our storage tank, and the replacement and service of our mains. We are very confident that our water production and delivery systems will provide superior services to you, our neighbors.

We have the greatest confidence in the service and vigilance of our Water Department employees and their commitment to provide quality water to you and your families.

Sincerely,

*Scott P. Strauss
Mayor*

INTRODUCTION

To comply with State regulations, the Incorporated Village of Mineola will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact the Supervisor of Water Plant Operations at the Mineola Water Department Office, (516) 746-0751, located at 167 Elm Place, Mineola, NY 11501, the EPA Safe Drinking Water Hotline (1-800-426-4791), or the Nassau County Department of Health at (516) 227-9692. We want our valued customers to be informed about your drinking water. If you want to learn more, please visit the EPA's website at <http://www.epa.gov/safewater/>, the New York State Department of Health's website at <http://www.health.state.ny.us/>, and attend any of our regularly scheduled village board meetings on the first and third Wednesday of each month.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for the public health.

One hundred percent of the water distributed to the Village's consumers is pumped from wells that obtain water from aquifers underlying northwest Nassau County. The water levels in the aquifers furnishing water to the Village dropped in the drought period of the mid-1960s and have risen in response to generally favorable precipitation that has occurred between 1970 and 2011. Available well supply from the aquifers has not diminished.

The Inc. Village of Mineola water system includes five wells. They are located on Elm Place, Westbury Avenue, Roselle Street, Washington Avenue, and Old Country Road. The Village is 100% metered and has an active cross connection control program in compliance with the State sanitary code.

During 2011, our system did not experience any restriction of our water source. As required by the Nassau County Department of Health, the Village disinfects its water supply by continuously adding sodium hypochlorite solution to Wells No. 1, 4, and 5 in an amount necessary to maintain a minimum of 0.2 milligrams per Liter (mg/L) chlorine residual. Wells No. 6 and 7 use a tablet calcium

hypochlorite chlorinator to maintain necessary chlorine residual. Sodium hydroxide is routinely added at all well stations in an amount necessary to maintain a pH level between 7.5 and 8.5 and to reduce corrosivity.

The two wells located on Old Country Road and Washington Avenue are treated to remove volatile organic chemicals using packed tower aeration (stripping towers). The process is completely natural by which air is delivered through the packing media in the tower past the cascading water to remove the volatiles from the water. The treated water discharges from the tower to a clear well where it is pumped to the distribution system.

The Nassau County Department of Health completed a Source Water Assessment Program for the Inc. Village of Mineola. Possible and actual threats to this drinking water source were evaluated. The source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how rapidly contaminants can move through the subsurface to the wells. The susceptibility of a water supply well to contamination is dependent upon both the presence of potential sources of contamination within the well's contributing area and the likelihood that the contaminant can travel through the environment to reach the well. The susceptibility rating is an estimate of the potential for contamination of the source water; it does not mean that the water delivered to consumers is, or will become contaminated. See the section "ARE THERE CONTAMINANTS IN OUR DRINKING WATER?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters in the future.

Drinking water is derived from 5 wells. The source water assessment has rated most of the wells as having a very high susceptibility to industrial solvents and a high susceptibility to nitrates. The very high susceptibility to industrial solvents is due primarily to point sources of contamination related to transportation routes and commercial/industrial facilities and related activities in the assessment area. The high susceptibility to nitrate contamination is attributable to residential and commercial land use and related practices in the assessment area, including fertilizing lawns.

A copy of the assessment, including a map of the assessment area, can be obtained by contacting the Nassau County Department of Health.

FACTS AND FIGURES

The total water produced in 2011 was 1,092.274 million gallons. The daily average of water treated and pumped into the distribution system was 2.99 million gallons. Our highest single day was 5.237 million gallons which occurred on July 21, 2011. The amount of water delivered to customers was 997.247 million gallons. Unaccounted-for water is estimated at 8.7%. This water was used to flush mains; fight fires; fill road sweepers and tanker trucks; and during water main breaks, leakage in mains and water services, and other authorized use of municipal operations. The Inc. Village of Mineola water rate schedule is described in Table 2 at the end of the report.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, Escherichia coliform, turbidity, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. A supplement to this report showing laboratory results of analysis of all samples (treated and untreated) taken from each water supply well in service and from the distribution system is available upon request. Contact the Supervisor of Water Plant Operations at the Mineola Water Department Office, (516) 746-0751, located at 167 Elm Place, Mineola, NY 11501.

Contamination of the groundwater from the Inc. Village of Mineola has been detected in samples from some wells. All groundwater pumped to the distribution system from the operating Water Department wells complies with New York State Department of Health Standards for public drinking water supplies. It should be noted that all drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791) or the Nassau County Department of Health at (516) 227-9692.

The table presented below, Table 1, shows the results of our monitoring for the period of January 1 to December 31, 2011. Table 1 depicts which compounds were detected in your drinking water. Not included in the table are the more than 80 other contaminants which were tested for and not detected in the system. These undetected contaminants are listed herein:

Organics (including Other Principal Organics and Synthetic Organics) – dichlorodifluoromethane, chloromethane, vinyl chloride, bromomethane, chloroethane, trichlorofluoromethane, 1,1-dichloroethene, methylene chloride, trans-1,2-dichloroethene, 1,1-dichloroethane, 2,2-dichloropropane, bromochloromethane, 1,1,1-trichloroethane, carbon tetrachloride, 1,1-dichloropropene, 1,2-dichloroethane, benzene, 1,2-dichloropropane, dibromomethane, cis-1,3 dichloropropene, toluene, trans-1,3-dichloropropene, 1,1,2-trichloroethane, 1,3-dichloropropane, chlorobenzene, 1,1,1,2-tetrachloroethane, ethylbenzene, m,p-xylene, o-xylene, styrene, isopropylbenzene, bromobenzene, 1,1,2,2-tetrachloroethane, 1,2,3-trichloropropane, n-propylbenzene, 2/4-chlorotoluene, 1,3,5-trimethylbenzene, tert-butylbenzene, 1,2,4-trimethylbenzene, sec-butylbenzene, n-butylbenzene, 1,3-dichlorobenzene, 1,4-dichlorobenzene, 4-isopropyltoluene, 1,2-dichlorobenzene, 1,2,4-trichlorobenzene, hexachlorobutadiene, 1,2,3-trichlorobenzene, 1,2-dibromoethane and 1,2-dibromo-3-chloropropane.

Microbiological – Total Coliform, Escherichia Coliform (E-Coli) and Turbidity.

Inorganics and Physical Characteristics - alkalinity-phen., ammonia nitrogen (as N), arsenic, beryllium, cadmium, chromium, cobalt, MBAS, fluoride, free cyanide, mercury, nitrite, odor, selenium, silver, thallium and vanadium.

Disinfection By-Products [Trihalomethanes (THMs) and Haloacetic Acids (HAA5s)] – total trihalomethanes, bromodichloromethane, chloroform, chloroacetic acid, bromoacetic acid, dichloroacetic acid, trichloroacetic acid, dibromoacetic acid and total haloacetic acid.

The most recent radiological sampling took place in 2010. Samples were collected from the Village wells and analyzed for gross alpha and radium-228 activities, measured in picocuries per Liter (pCi/L). The maximum contaminant level for gross alpha radioactivity in water is 15 pCi/L for an average of four quarterly samples. The average of the gross alpha samples collected in 2010 was 1.979 pCi/L. The maximum contaminant level for radium -228 in water is 5 pCi/L for an average of four quarterly samples. The average of radium-228 samples collected in 2010 was 1.254 pCi/L. In accordance with State regulations, the Inc. Village of Mineola will discontinue distribution monitoring for radiological contaminants.

The most recent lead and copper sampling took place in 2010. Samples were collected from the distribution system at 30 residential points and analyzed for lead and copper. Lead is measured in micrograms per liter (ug/L). The Action Level (AL) for lead is 15 ug/L. The level of lead presented in Table 1, 4.46 ug/L, represents the 90th percentile of the 30 sites tested. The AL for lead was not exceeded at any of the sites tested. Copper is measured in milligrams per liter (mg/L). The AL for copper is 1.3 mg/L. The level of copper presented in Table 1, 0.32 mg/L, represents the 90th percentile of the 30 sites tested. The AL for copper was exceeded at one of the sites tested.

The highest level of a contaminant that is allowed in drinking water is known as the Maximum Contaminant Level (MCL). The level of a contaminant below which there is no known or expected risk to health is known as the Maximum Contaminant Level Goal (MCLG). MCLGs allow for a margin of safety.

The highest level of a disinfectant allowed in drinking water is known as the Maximum Residual Disinfectant Level (MRDL). There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants. The level of a drinking water disinfectant below which there is no known or expected risk to health is known as the Maximum Residual Disinfectant Level Goal (MRDLG). MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow is known as the Action Level (AL).

SEE TABLE 1 PAGE 7

We also are required to present the following information on lead in drinking water:

Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease-causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, persons with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia, and other microbial pathogens are available from the Safe Drinking Water Hotline (1-800-426-4791).

INFORMATION ON UNREGULATED CONTAMINANTS

Unregulated contaminants are those for which the EPA has not established drinking water standards. The Inc. Village of Mineola is monitoring for additional contaminants under the EPA's Unregulated Contaminant Monitoring Regulation (UCMR). The information collected under the UCMR will help the EPA determine future drinking water regulations. The results of the monitoring program are available upon request.

INFORMATION FOR NON-ENGLISH SPEAKING RESIDENTS

Spanish

Este informe contiene información muy importante sobre su agua beber. Tradúzcalo ó hable con alguien que lo entienda bien.

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Water is a vital resource. The Inc. Village of Mineola encourages water conservation. Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;

Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems, and water towers;

Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met;

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.

Turn off the tap when brushing your teeth.

Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.

- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water-using appliances, then check the meter after 15 minutes. If it moved, you have a leak.
- Water your lawn in the early morning to reduce water loss by evaporation.

SYSTEM IMPROVEMENTS

In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements.

System improvements planned for 2012 include the rehabilitation of Well No. 6 and well maintenance overhaul.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. The Incorporated Village of Mineola works hard to provide top quality water to every customer. We ask that all our customers help us protect our water resources.

TABLE 1

| Contaminant | Violation Yes / No | Date of Sample | Level Detected: Avg / Max (Range) (1) | Unit Measurement | MCLG or MRDLG | Regulatory Limit (MCL, MRDL, or AL) | Likely Source of Contamination |
|---------------------------------|--------------------|----------------|---------------------------------------|------------------|---------------|-------------------------------------|--|
| Inorganics | | | | | | | |
| Antimony | No | 5/12/2011 | 1.05 (ND - 1.05) | ug/L | 6 | 6 | Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder |
| Barium | No | 12/1/2011 | 0.0032 (ND - 0.0032) | mg/L | 2 | 2 | Discharge of drilling wastes; Erosion of natural deposits |
| Calcium | No | 4/5/2011 | 16.1 (3.31 - 16.1) | mg/L | n/a | n/a | Naturally occurring |
| Chloride | No | 3/1/2011 | 27.9 (7.1 - 27.9) | mg/L | n/a | MCL - 250 | Naturally occurring or indicative of road salt contamination |
| Copper (2) | No | 5/10/2010 | 0.32 (ND - 0.86) | mg/L | 1.3 | AL - 1.3 | Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives |
| Iron (3) | No | 8/9/2011 | 57 (ND - 57) | ug/L | n/a | MCL - 300 | Naturally occurring |
| Dissolved Iron (3) | No | 12/1/2011 | 40 (ND - 40) | ug/L | n/a | MCL - 300 | Naturally occurring |
| Lead (4) | No | 8/10/2010 | 4.46 (ND - 8.35) | ug/L | 0 | AL - 15 | Corrosion of household plumbing systems; Erosion of natural deposits |
| Magnesium | No | 5/12/2011 | 5.41 (2.9 - 5.41) | mg/L | n/a | n/a | Naturally occurring |
| Manganese (2) | No | 8/9/2011 | 23 (ND - 23) | ug/L | n/a | MCL - 300 | Naturally occurring; indicative of landfill contamination |
| Dissolved Manganese (2) | No | 8/4/2011 | 20 (ND - 20) | ug/L | n/a | MCL - 300 | Naturally occurring; indicative of landfill contamination |
| Nickel | No | 12/1/2011 | 0.0013 (ND - 0.0013) | mg/L | n/a | n/a | Naturally occurring |
| Ortho-Phosphate-P | No | 8/4/2011 | 0.31 (ND - 0.31) | mg/L | n/a | n/a | Naturally occurring |
| Phosphorus | No | 5/11/2011 | 0.83 (ND - 0.83) | mg/L | n/a | n/a | Naturally occurring |
| Potassium | No | 8/9/2011 | 1.5 (1 - 1.5) | mg/L | n/a | n/a | Naturally occurring |
| Silicon Dioxide | No | 8/23/2011 | 11.2 (10.5 - 11.2) | mg/L | n/a | n/a | Naturally occurring |
| Sodium | No | 5/12/2011 | 57.8 (14.9 - 57.8) | mg/L | n/a | 20 / 270 (5) | Naturally occurring |
| Sulfate | No | 12/1/2011 | 16 (4 - 16) | mg/L | n/a | MCL - 250 | Naturally occurring |
| Zinc | No | 8/23/2011 | 0.023 (ND - 0.023) | mg/L | n/a | MCL - 5 | Naturally occurring |
| Inorganics - Nitrate | | | | | | | |
| Nitrate | No | 6/16/2011 | 5.59 (2.8 - 5.59) | mg/L | 10 | MCL - 10 | Runoff from fertilizer use; Leaching from septic tanks and sewage; Erosion of natural deposits |
| Physical Characteristics | | | | | | | |
| Calcium Hardness | No | 5/12/2011 | 32 (ND - 32) | mg/L | n/a | n/a | Naturally occurring |
| Langlier Saturation Index | No | 12/1/2011 | -0.88 | units | n/a | n/a | Naturally occurring |
| pH | No | 10/11/2011 | 8.1 (6.6 - 8.1) | units | n/a | n/a | Naturally occurring |
| Specific Conductance | No | 7/22/2011 | 358 (128 - 356) | umhos/cm | n/a | n/a | Naturally occurring |
| Total Alkalinity | No | 12/1/2011 | 116 (90 - 116) | mg/L | n/a | n/a | Naturally occurring |
| Total Dissolved Solids | No | 12/1/2011 | 151 | mg/L | n/a | n/a | Naturally occurring |
| Total Hardness | No | 5/12/2011 | 54.2 (22 - 54.2) | mg/L | n/a | n/a | Naturally occurring |
| Disinfectant | | | | | | | |
| Chlorine Residual | No | 6/10/2011 | 0.3 (0.2 - 3.0) | mg/L | n/a | MRDL - 4 (6) | Water additive used to control microbes |
| Disinfection By-Products | | | | | | | |
| Bromoform | No | 5/12/2011 | 0.75 (ND - 1.3) | ug/L | n/a | MCL - 80 | By-product of drinking water chlorination needed to kill harmful organisms. |
| Dibromochloromethane | No | 5/12/2011 | 0.37 (ND - 0.6) | ug/L | n/a | MCL - 80 | By-product of drinking water chlorination needed to kill harmful organisms. |
| Organic Contaminants | | | | | | | |
| cis-1,2-Dichloroethene | No | 12/1/2011 | 1 (ND - 1) | ug/L | n/a | MCL - 5 | Discharge from industrial chemical factories |
| Methyl Tert-Butyl Ether | No | 12/1/2011 | 0.6 (ND - 0.6) | ug/L | n/a | MCL - 10 | Releases from gasoline storage tanks; Atmospheric deposition |
| Tetrachloroethene | No | 12/1/2011 | 1.7 (ND - 1.7) | ug/L | n/a | MCL - 5 | Discharge from factories and dry cleaners; Waste sites; Spills |
| Trichloroethene | No | 9/1/2011 | 1.66 (ND - 4.2) | ug/L | 0 | MCL - 5 | Discharge from metal degreasing sites and other factories |
| Radioactive Contaminants | | | | | | | |
| Gross Alpha | No | 12/13/2010 | 1.979 (0.613 - 3.47) (7) | pCi/L | 0 | MCL - 15 | Erosion of natural deposits |
| Radium-226 | No | 12/13/2010 | 1.254 (1.01 - 1.58) (7) | pCi/L | 0 | MCL - 5 | Erosion of natural deposits |

Notes:

- (1) When compliance with the MCL is determined more frequently than annually, the value reported is the maximum levels or highest average of any of the sampling points used to determine compliance and the range of detected levels.
- (2) The level presented represents the 90th percentile of the 30 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, thirty samples were collected at your water system and the 90th percentile value was the twenty-seventh highest value (0.32 mg/L). The action level for copper was exceeded at one of the sites tested.
- (3) The NYS DOH mandates that if iron and manganese are present, the total concentration of both should not exceed 500 ug/L.
- (4) The level presented represents the 90th percentile of the 30 sites tested. The action level for lead was not exceeded at any of the sites tested.
- (5) Water containing more than 20 mg/L of sodium should not be used for drinking by people on severely-restricted sodium diets. Water containing more than 270 mg/L of sodium should not be used for drinking by people on moderately-restricted sodium diets.
- (6) The value presented represents the Maximum Residual Disinfectant Level (MRDL). MRDLs are not currently regulated, but in the future they will be enforceable in the same manner as MCLs.
- (7) The contaminant level represents the average of raw water samples taken from multiple wells. The data is reported as the average level and the range of detected levels.

Definitions:

MCL: Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water; MCLs are set as close to the MCLGs as feasible.
MCLG: Maximum Contaminant Level Goal, the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL: Maximum Residual Disinfectant Level, the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG: Maximum Residual Disinfectant Level Goal; The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.
ND: Non-Detect, laboratory analysis indicates that the constituent is not present.
AL: Action Level, the concentration of a contaminant that, if exceeded, triggers treatment or other requirements which a water system must follow.
umhos/cm: Micro ohms per centimeter.
mg/L: Milligrams per Liter; Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).
ug/L: Micrograms per Liter; Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).
pCi/L: PicoCuries Per Liter; A measure of the radioactivity in water.
n/a: not applicable; i.e., no value is assigned by regulatory authorities.

Table 2
INCORPORATED VILLAGE OF MINEOLA
WATER DEPARTMENT
Water Rate Schedule

Category A
One Family and Two Family Residences

| Costs (dollars per 1,000 gallons) | | | | | | |
|-----------------------------------|-----------------------|-----------|-----------|-----------|-----------|--------------|
| Minimum Charge | Entitlement (Gallons) | 10-20,000 | 20-30,000 | 30-40,000 | 40-75,000 | Above 75,000 |
| \$20.00 | 10,000 | \$1.75 | \$2.25 | \$2.50 | \$2.75 | \$3.00 |

Category B

Commercial Accounts - Monthly Accounts

| Costs (dollars per 1,000 gallons) | | | | | | |
|-----------------------------------|--------------|----------|-----------|-----------|-----------|--------------|
| Meter Size (inches) | Meter Charge | 0-20,000 | 20-40,000 | 40-60,000 | 60-80,000 | Above 80,000 |
| 5/8 | \$75.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 3/4 | \$75.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 1 | \$75.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 1 1/2 | \$150.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 2 | \$200.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 3 | \$275.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 4 | \$375.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 5 | \$525.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 6 | \$625.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 8 | \$1,025.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |

Category C

Commercial Accounts - Semi Annual Billing

| Costs (dollars per 1,000 gallons) | | | | | | |
|-----------------------------------|--------------|----------|-----------|-----------|-----------|--------------|
| Meter Size (inches) | Meter Charge | 0-10,000 | 10-20,000 | 20-30,000 | 30-40,000 | Above 40,000 |
| 5/8 | \$37.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 3/4 | \$37.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 1 | \$37.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 1 1/2 | \$75.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 2 | \$100.00 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 3 | \$137.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 4 | \$187.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 5 | \$262.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 6 | \$312.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |
| 8 | \$512.50 | \$1.75 | \$2.25 | \$2.75 | \$3.25 | \$3.75 |

Presort Standard
 U.S. Postage
PAID
 Mineola, NY
 Permit No. 12

ECRWSS
RESIDENTIAL CUSTOMER
LOCAL

