

# 2013 drinking water quality report

FRANKLIN SQUARE WATER DISTRICT  
PUBLIC WATER SUPPLY IDENTIFICATION NO. 2902822

## ANNUAL WATER SUPPLY REPORT

MAY 2014

To keep our customers up-to-date on the quality of our drinking water the Franklin Square Water District is pleased to present this year's Water Quality Report. New York State and the EPA set regulations for drinking water quality and indicate the levels of various substances that are acceptable in public drinking water. This report explains how our water supply compares to the standards that the State and the EPA have developed.


Our constant goal is to provide you with a safe and dependable supply of drinking water every single day. The Board of Water Commissioners and the District employees are committed to ensuring that you and your family receive the highest quality water.

## WHERE DOES OUR WATER COME FROM?

A water supply system can consist of surface water (water that comes from rivers, lakes, streams, ponds, reservoirs) or groundwater. Our water supply source is groundwater. We have five (5) wells located throughout our community that pump water out of the Magothy aquifer which is located beneath the land surface of Long Island as shown in the adjacent drawing. Aquifers are underground layers of porous rock and sand that store about 50 percent of the rain and snow that fall on Long Island.

In order to ensure that our tap water is safe to drink, the State and the EPA prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

The population within the Franklin Square Water District during 2013 was 20,000. The total amount of water withdrawn from the aquifer during the year was 773.5 million gallons.



THE LONG ISLAND AQUIFER SYSTEM

## WATER CONSERVATION MEASURES

The underground water system of Long Island has more than enough water for present water demands. However, saving water can reduce your water bill and most importantly will ensure that our future generations will have a safe and abundant water supply.

We would like to thank the residents who have begun implementing water conservation measures in their homes. We hope that making some small changes continues as the trend in 2013 and years to come. Some of the steps that can be made to conserve water are:

- Check for repair leaks in the home. A slow drip can waste 15 to 20 gallons a day!!
- Replace showerheads, faucets and toilets with water-saving devices or retrofitting existing plumbing fixtures with flow restrictors.
- Try to maintain an awareness of personal and family habits that can lead to water conservation. For example, don't let the faucet run when it isn't in use!

Modify automatic lawn sprinklers to include rain sensors and don't forget - Nassau County Lawn Sprinkler Regulations are still in effect.

But we aren't leaving all conservation efforts to the consumers. The Franklin Square Water District has been implementing our own water conservation measures. In 2013, we continued to implement a water conservation program in order to minimize any unnecessary water use. The pumpage for 2013 was approximately 5.0 percent more than in 2012. This was most likely due to the slightly hotter and drier weather during summer months in 2013. We will remain dedicated to implementing water conservation measures at our wells and throughout the distribution system. Additional education material are available at the District office.

# WATER QUALITY FACTS

In accordance with State regulations, the Franklin Square Water District routinely monitors your drinking water for numerous parameters. We test your drinking water for coliform bacteria, turbidity, inorganic contaminants, lead and copper, nitrates, volatile organic contaminants and synthetic organic contaminants. Over 135 separate parameters are tested for in each of our wells numerous times per year. The table presented on page 3 depicts which parameters or contaminants were detected in your drinking water. It should be noted that many of these parameters are naturally found in all Long Island drinking water and do not pose any adverse health effects.

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as person with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

The District implements several measures to protect the quality of water. One of these measures is maintaining an active backflow prevention program where plumbing devices are installed on water services to prevent the backflow of any contaminant into the distribution system. The District requires all residents with automatic sprinkler systems to maintain a backflow device. Please contact the District office for the District's backflow requirements.

## WHAT TYPE OF WATER TREATMENT DO WE PROVIDE?

The Franklin Square Water District provides treatment at all wells to improve the quality of the water pumped prior to distribution to the consumer. The pH of groundwater is normally a bit low, so to reduce any corrosion in water mains and in-house plumbing, sodium hydroxide is added to the water to raise the pH.

The soil and water at Well No. 3 have a high level of iron. Although iron does not cause a health hazard, it does stain laundry and plumbing fixtures. A sequestering agent in the form of polyphosphate is added to the water at Well No. 3 to stabilize the iron in the water. At Well Nos. 4 and 5, a granular activated carbon (GAC) filter system is installed for the removal of organic compounds that have been found in the water. The District constructed an air stripping treatment facility to remove organic compounds from Well Nos. 1 and 2.

The District also adds small amounts of sodium hypochlorite to the water as a disinfection agent.

The Franklin Square Water District conducts over 5,000 water quality tests throughout the year, testing for over 130 different contaminants which have been undetected in our water supply including:

Turbidity	Hexachlorocyclopentadiene	Chloromethane	1,2,3-Trichlorobenzene
Odor	bis(2-Ethylhexyl)adipate	Vinyl Chloride	Benzene
Ammonia	bis(2-Ethylhexyl)phthalate	Bromomethane	Toluene
Nitrite	Hexachlorobenzene	Chloroethane	Ethylbenzene
Detergents (MBAS)	Benzo(A)Pyrene	Trichlorofluoromethane	M,P-Xylene
Free Cyanide	Aldicarb Sulfone	Chlorodifluoromethane	O-Xylene
Antimony	Aldicarb sulfoxide	Methylene Chloride	Styrene
Beryllium	Aldicarb	Trans-1,2-Dichloroethene	Isopropylbenzene (Cumene)
Thallium	Total Aldicarbs	1,1-Dichloroethane	N-Propylbenzene
Lindane	Oxamyl	cis-1,2-Dichloroethene	1,3,5-Trimethylbenzene
Heptachlor	Methomyl	2,2-Dichloropropane	Tert-Butylbenzene
Aldrin	3-Hydroxycarbofuran	Bromochloromethane	1,2,4-Trimethylbenzene
Heptachloro Epoxide	Carbofuran	Carbon Tetrachloride	Sec-Butylbenzene
Dieldrin	Carbaryl	1,1-Dichloropropene	4-Isopropyltoluene (P-Cumene)
Endrin	Glyphosate	1,2-Dichloroethane	N-Butylbenzene
Methoxychlor	Diquat	1,2-Dichloropropane	Methyl Tert. Butyl Ether (MTBE)
Toxaphene	Endothall	Dibromomethane	Selenium
Chlordane	1,2-Dibromoethane (EDB)	Trans-1,3-Dichloropropene	
Total PCBs	1,2-Dibromo-3-Chl. Propane	cis-1,3-Dichloropropene	
Propachlor	Dioxin	1,2-Dichlorobenzene	
Alachlor	Chloroacetic Acid	1,3-Dichlorobenzene	
Simazine	Bromoacetic Acid	1,4-Dichlorobenzene	
Dicamba	Gross Beta	1,2,4-Trichlorobenzene	
Pentachlorophenol	Dichlorodifluoromethane	Hexachlorobutadiene	

# 2013 DRINKING WATER QUALITY REPORT - TABLE OF DETECTED PARAMETERS

Contaminants	Violation (Yes/No)	Date of Sample	Level Detected (Maximum Range)	Unit Measurement	MCLG	Regulatory Limit (MCL or AL)	Likely Source of Contaminant
<b>Inorganic Contaminants</b>							
Copper	No	June -September 2011	ND-0.17 <sup>(1)</sup>	ug/l	1.3	AL = 1.3	Corrosion of household plumbing systems; Erosion of natural deposits
Lead	No	June -September 2011	ND - 4.57 <sup>(1)</sup>	mg/l	0	AL = 15	Corrosion of household plumbing systems; Erosion of natural deposits
Barium	No	08-23-13	ND - 0.003	mg/l	n/a	MCL = 2	Naturally occurring
Sodium	No	08-09-13	ND - 25.5	mg/l	n/a	No MCL <sup>(2)</sup>	Naturally occurring
Zinc	No	08-23-13	ND - 0.05	mg/l	n/a	MCL = 5	Naturally occurring
Chloride	No	08-23-13	14.4 - 37.2	mg/l	n/a	MCL = 250	Naturally occurring
Iron	Yes <sup>(3)</sup>	08-23-13	ND - 1730	ug/l	n/a	MCL = 300	Naturally occurring
Manganese	No	08-23-13	ND - 80	ug/l	n/a	MCL = 300	Naturally occurring
Nitrate	No	08-02-13	ND - 2.1	mg/l	10	MCL = 10	Runoff from fertilizer and leaching from septic tanks and sewage
Sulfate	No	08-23-13	8.7 - 52.3	mg/l	n/a	MCL = 250	Naturally occurring
Magnesium	No	08-23-13	3.0 - 7.2	mg/l	n/a	None	Naturally occurring
Nickel	No	08-23-13	0.001 - 0.005	mg/l	n/a	MCL = 0.1	Naturally occurring
Calcium	No	08-23-13	4.7 - 13.9	mg/l	n/a	None	Naturally occurring
Perchlorate	No	08-02-13	ND - 1.0	ug/l	n/a	AL = 18 <sup>(3)</sup>	Fertilizer, road flares, matches
<b>Bacteriologicals</b>							
Total Coliform <sup>(4)</sup>	Yes	08-23-13	3 out of 1,536	Positive or Negative	--	MCL = Positive results in more than 5% of the monthly samples	Commonly found in the environment
<b>Volatile Organic Contaminants</b>							
1,1-Dichloroethene	No	12-10-13	ND - 2.4	ug/l	0	MCL = 5	Industrial discharge
1,1,1-Trichloroethane	No	11-02-13	ND - 1.3	ug/l	0	MCL = 5	Industrial discharge
Total Trihalomethanes (TTHMs)	No	--	ND	mg/l	0	MCL = 5	Disinfection By-Products
<b>Unregulated Contaminants</b>							
None Detected	--	--	ND	--	--	--	--
<b>Synthetic Organic Contaminants Including Pesticides and Herbicides</b>							
None Detected	--	--	ND	--	--	--	--
<b>Radionuclides</b>							
Gross Alpha	No	07-05-13	0.25 - 0.993	pCi/L	n/a	MCL = 50	Naturally occurring
Radium 226	No	07-13-13	0.06 - 0.706	pCi/L	n/a	MCL = 5	Naturally occurring
Radium 228	No	07-14-13	0.468 - 0.787	pCi/L	n/a	MCL = 5	Naturally occurring

## Definitions:

**Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Milligrams per liter (mg/l)** - Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Micrograms per liter (ug/l)** - Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Non-Detects (ND)** - Laboratory analysis indicates that the constituent is not present.

**pCi/L** - pico Curies per Liter is a measure of radioactivity in water.

<sup>(1)</sup> - During 2011, we collected and analyzed 30 samples for lead and copper. The 90% percentile level is presented in the table. The action levels for copper was not exceeded at any site tested. The action level for lead was exceeded at only one site. Retesting is required in 2014.

<sup>(2)</sup> - No MCL has been established for sodium. However, 20 mg/l is a recommended guideline for people on high restricted sodium diets and 270 mg/l for those on moderate sodium diets.

<sup>(3)</sup> - Iron is only a secondary water standard. Iron has no health effects. Therefore, exceeding the MCL represents a level at which adverse aesthetics effects start to occur. The maximum iron result shown in Well No. 3. The District only uses Well No. 3 during peak demand periods. The District also provides iron sequestering treatment when Well No. 3 is utilized. Typical iron concentrations from all other wells is normally undetectable.

<sup>(4)</sup> - Total coliform bacteria was detected in 3 out of 20 routine monthly compliance samples collected within our distribution system in August 2013. No positive samples were detected for the rest of the year. All repeat samples were negative for bacteria. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other potentially harmful bacteria may be present.

## COST OF WATER

The District bills its consumers at a billing rate of \$20.00 per quarter for the first 9,000 gallons and \$2.00 per additional 1,000 gallons. Of the 773.5 million gallons that was withdrawn, approximately 91 percent was billed directly to the consumers. The typical District resident pays approximately \$1.00 per day for water. We are sure you will agree that your water bill is by far the cheapest of all your utility bills.

Copies of the Supplemental Data Package, which includes the water quality data for each of our supply wells utilized during 2013, are available at the Franklin Square Water District office located at 895 Schroeter Avenue, Franklin Square, New York and the local Public Library.

We, at the Franklin Square Water District, work around the clock to provide top quality water to every tap throughout the community. The District is proud of the fact that we consistently are voted one of the Best Tasting Waters in Nassau County. We ask that all our customers help us protect our water supply, which is the heart of our community, our way of life and our children's future.

## PUBLIC INFORMATION AND PARTICIPATION

If you have any questions about this report or about your water supply, the following contacts and resources are available to you:

- 💧 Water District Business Manager Carmen DiMartino at (516) 354-0780.
- 💧 Nassau County Department of Health at (516) 227-9692.
- 💧 All our residents are welcome to attend any of our regularly scheduled meetings. They are normally held on the first, second, third and fourth Tuesday of each month at 4:00 p.m. at the Water District office.

The Franklin Square Water District routinely monitors for different parameters and contaminants in your drinking water as required by Federal and State laws. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. If you would like to find more information on contamination and potential health risks, you can contact:

- 💧 USEPA Safe Drinking Water Hotline at (800-426-4791).

Franklin Square Water District  
895 Schroeter Avenue  
Franklin Square, New York 11010

### **Board of Commissioners**

Salvatore A. Intagliata, Chairperson  
Ralph D. Pugliese, Treasurer  
Joseph V. Ra, Secretary

STANDARD MAIL  
U.S. Postage  
**PAID**  
Flushing, NY  
PERMIT No. 1331

ADDRESS CORRECTION REQUESTED